


Performance Testing

Blower Door Test
Thermal Imaging
Comfort




Blower Door Test Results:

Office Volume: 33,600 CF

204 CFM @ - 50 PA


$204 \times 60 / 33,600 =$

3.6 ACH 50



THERMAL BRIDGING







SCHEDULE:

1. Building possession – July 1, 2015
2. Start work on site – December 15, 2015
3. Start work on Passive office area – February 15, 2016
4. Office occupancy – August 1, 2016

Total Duration of work on Building = 7.5 Months

Office area work duration - +/- **5 Months**

BUDGET

Total office related construction - \$410,000

Estimated PH related expenses:

\$5,000 Insulation

\$3,000 Windows

\$3,500 ERV

\$6,000 Air sealing membranes and tapes

\$15,000 Extra labor to air seal & Insulate

= \$32,500 Extra Expenses

- Mechanical system savings?

PH = approximately 8% of Construction Cost